

COUNTY LOCAL LAWS

ARRANGEMENT THAT IS APPROVED BY THE ADMINISTRATIVE AUTHORITY.

717.2 SIZE

FLOOR DRAINS SHALL BE OF THE SIZE TO SERVE EFFICIENTLY THE PURPOSE FOR WHICH IT IS INTENDED. TRAPS SHALL MEASURE NOT LESS THAN THREE INCHES (3"), PROVIDED THEY MAY BE REDUCED TO A MINIMUM OF TWO INCHES (2") WHEN SPECIFIC APPROVAL IS GIVEN BY THE ADMINISTRATIVE AUTHORITY.

717.3 PERMITTED FLOOR DRAINS

WHEN APPROVED BY THE ADMINISTRATIVE AUTHORITY, FLOOR DRAINS MAY BE INSTALLED IN BASEMENTS, UTILITY ROOMS, COMMERCIAL KITCHENS, FOOD PROCESSING ESTABLISHMENTS, PUBLIC REST ROOMS, AND IN OTHER LOCATIONS WHERE THEY MAY HELP PROMOTE THE CLEANLINESS OF THE BUILDING.

717.4 ACCESSIBILITY

FLOOR DRAINS SHALL BE SO CONSTRUCTED THAT THEY CAN BE READILY CLEANED.

717.5 BELL TRAPS

BELL TRAPS ARE PROHIBITED.

(19) SECTION 804 PLASTIC PIPE SUPPORTS

804.1 PLASTIC PIPE SUPPORTS

HANGERS AND STRAPS SHALL NOT COMPRESS, DISTORT, CUT, OR UPGRADE THE PIPING AND SHALL ALLOW FREE MOVEMENT OF THE PIPE. PIPES SHALL BE SUPPORTED AT INTERVALS OF NOT MORE THAN FOUR FEET (4') AT END OF BRANCHES, AND AT CHANGE OF DIRECTION OR ELEVATION. SUPPORTS SHALL ALLOW FREE MOVEMENT. VERTICAL PIPING SHALL BE MAINTAINED IN STRAIGHT ALIGNMENT. TRAP ARMS IN EXCESS OF THREE FEET (3') SHALL BE SUPPORTED AS CLOSE AS POSSIBLE TO THE TRAP.

804.2 UNDERGROUND INSTALLATION

THE TRENCH BOTTOM SHALL BE SMOOTH AND OF UNIFORM GRADE, WITH EITHER UNDISTURBED GROUND OR A LAYER OF SELECTED AND COMPACTED BACKFILL SO THAT NO SETTLEMENT SHALL BE ENCOUNTERED. PIPE MUST BEAR ON THIS MATERIAL THROUGHOUT THE ENTIRE LENGTH OF ITS BURIAL.

(20) SECTION 805 IN GROUND